

Loss reduction of transmission lines using PSO-based optimum performance of UPFC

Shaimaa A. Hussein¹, Dhari Yousif Mahmood¹, Ali Hussein Numan²

¹Department of Electrical Engineering, University of Technology, Baghdad, Iraq

²Department of Electromechanical Engineering, University of Technology, Baghdad, Iraq

Article Info

Article history:

Received Aug 14, 2022

Revised Oct 10, 2022

Accepted Nov 12, 2022

Keywords:

Flexible alternating current
transmission systems
Loss minimization
Particle swarm optimization
Proportional-integral controller
Unified power flow controller

ABSTRACT

Transmission line losses are one of the essential topics and issues in power systems research. Several methods and techniques have been used to reduce these losses, and one of these modern techniques is flexible alternating current transmission systems (FACTS). In this paper, one of the most important types of this technology, the unified power flow controller (UPFC), was used to reduce losses in the Iraqi national grid (ING) 400 kV. This paper presents an efficient method for minimizing losses of transmission lines in the ING system (400 kV) 46-bus approach. A particle swarm optimization (PSO)-based optimum proportional-integral (PI) controller with UPFC was proposed to obtain the optimal location of UPFC and optimum parameters of the PI controller to achieve the objective function of the research. MATLAB coded the algorithm. The Newton-Raphson method was employed to perform load flow analysis. The results showed that the best place for UPFC is buses (14-17) named BGE4 (Baghdad)-AMN4 (Baghdad), and the total active power and reactive power losses decreased from 727.4593 to 579.3874 MW and from 5155.9 to 3971.1 MVAR, respectively and also led to voltage regulation.

This is an open access article under the [CC BY-SA](#) license.



Corresponding Author:

Shaimaa A. Hussein
Department of Electrical Engineering, University of Technology
Baghdad, Iraq
Email: eee.20.56@grad.uotechnology.edu.iq

1. INTRODUCTION

Transmission lines are now under more pressure than ever and thus have a greater chance of line failure due to increased demand for electricity and an inability to keep pace due to resource and environmental constraints. Improving system reliability and safety can be as simple as installing new transmission lines. But due to political and environmental factors, this becomes a long process. New technology is being developed to make the electric grid more reliable and safe, such as flexible alternating current transmission systems (FACTS) [1]. The FACTS technology is astonishingly and swiftly integrated with power transmission networks. It can give power transmission lines the boost they need, especially the unified power flow controller (UPFC) type; two converters and two transformers are included, one connected in series with the transmission line and the other in parallel. UPFC controls the flow of actual and reactive power through the transmission line independently by inserting voltage into the transmission line [2]–[4].

Minimizing power losses is one of the primary goals of installing FACTS devices in power grids; therefore, almost all articles dealing with these devices have addressed this issue [5]–[9]. Numerous authors have looked into the advantages of UPFC placement on system performance. However, the best placements for UPFC devices are essential due to their high price. Several strategies, including classical, heuristic, and mixed techniques, are available in the literature for resolving these FACTS optimisation problems. However,

all of these methods have disadvantages in addition to their advantages. Heuristics techniques such as genetic algorithms (GA), differential evolution, particle swarm optimisation (PSO), evolutionary programming, and evolution strategies are commonly employed for optimisation problems. These techniques can calibrate optimal outcomes with less complexity [10].

Research by Kashyap and Rahangdale [11], PSO is used to fix many problems with electrical power transmission networks. It can reduce system losses, improve line voltages, and increase transmission capacity. Salman *et al.* [12] employed GA to identify the best location for UPFC devices to optimize voltage profiles, reduce power losses, control power flow in overloaded transmission lines, and decrease power generation in the local Iraqi network (Diyala 132 kV). Two types of artificial algorithms, imperialist competitive algorithm (ICA) and PSO, were compared in [13], and FACTS devices effects are displayed to minimize network losses. It has been shown that the PSO algorithm with UPFC reduces both active and reactive power losses more than other FACTS device types and intelligent algorithms. Although UPFC has several advantages, its controller design remains a problem because it is a multi-variable controller. Numerous control strategies have been implemented to control UPFC for various power system applications. Qader [14] proposed a systematic technique based on optimal control and tracking with a proportional-integral (PI) controller for the UPFC, desired steady-state behaviour, and a linear quadratic tracker, MATLAB/Simulink model. Deka *et al.* [15] presents the MATLAB/Simulink fuzzy UPFC model based on PI to improve the power quality by correcting the load voltage and changing the active and reactive power. El-Emari *et al.* [16] proposed an optimized PI-derivative (PID) controller for the UPFC; the suggested system uses the algorithm (ICA) to determine the optimal PID free gain values. After optimizing the controller, it is applied to a simple standard procedure, and the results show that the proposed method works well. According to Romasevych *et al.* [17], the gains of the PI controller were calibrated using the PSO; the control system under consideration was a PI controller cascaded with a general plant. Roslan *et al.* [18] proposed a PSO algorithm to improve the performance of the PI controller in a real-time simulation system by finding the optimum values for the PI controller parameters. All of this research implemented the control by Simulink. The following points are the primary contributions of this paper: i) proposed PSO-based optimum PI controller parameters to find the optimum performance of UPFC by controlling the voltage of the two converters of the UPFC device and finding the optimal location of this device. The proposed algorithm is coded in MATLAB code (M-file); ii) the objective function of the research is to minimize the transmission line's active and reactive power loss; and iii) the proposed method is tested on the Iraqi national grid (ING) (46-bus) system.

2. PROPOSED METHOD

To achieve the objective mentioned in the paper's contributions. PSO is used to determine the optimal location of the UPFC and the optimum parameters of the PI controller. The study method is discussed thoroughly: UPFC modelling and the proposed PSO-based optimum PI controller with UPFC.

2.1. Unified power flow controller

The UPFC concept was proposed by Gyugyi [19]. The use of UPFC makes it possible to simultaneously control the impedance of a transmission line, the phase angle, the magnitude of the voltage, and the active and reactive power flow [20]–[23]. As shown in Figure 1 [12], UPFC comprises two voltage-sourced converters, one coupled in a shunt (i.e. STATCOM) and the other in a series (i.e. SSSC) [24], [25]. By injecting an AC voltage with a controllable magnitude and phase angle in series with the transmission line via a series-connected coupling transformer, the series converter performs the primary role of a UPFC. On the other hand, the main job of the shunt converter is to give or take the actual power that the series converter needs at the common DC link [26]. Figure 2 [12] shows the UPFC's electrical model.

The essential operation of UPFC and the needed to apply PSO to it to find the location and parameters of PI-based UPFC controller on the power transmission network ING (400 kV). As a result, (1) through (16) [12] are used to implement the PSO program. To achieve the given goals that will be discussed using in the following section:

$$E_{vR} = V_{vR}(\cos \delta_{vR} + j\sin \delta_{vR}) \quad (1)$$

$$E_{cR} = V_{cR}(\cos \delta_{cR} + j\sin \delta_{cR}) \quad (2)$$

$$\text{Re}\{-E_{vR}I_{vR}^* + E_{cR}I_m^*\} = 0 \quad (3)$$

$$\begin{bmatrix} I_K \\ I_m \end{bmatrix} = \begin{bmatrix} (Y_{cR} + Y_{vR}) & -Y_{cR} & -Y_{cR} & -Y_{vR} \\ -Y_{cR} & Y_{cR} & Y_{cR} & 0 \end{bmatrix} \begin{bmatrix} V_K \\ V_m \\ E_{cR} \\ E_{vR} \end{bmatrix} \quad (4)$$

where:

E_{vR}, E_{cR} : UPFC voltage sources

V_{vR} : the controllable magnitude supplying the shunt converter ($(V_{vR} \min) \leq V_{vR} \leq (V_{vR} \max)$)

δ_{vR} : the phase angle of the shunt converter ($0 \leq \delta_{vR} \leq 2\pi$)

V_{cR} : the controllable voltage magnitude supplying the series converter ($(V_{cR} \min) \leq V_{cR} \leq (V_{cR} \max)$)

δ_{cR} : the phase angle of the series converter ($0 \leq \delta_{cR} \leq 2\pi$) [12]

bus K:

$$P_K = V_K^2 G_{KK} + V_K V_m [G_{Km} \cos(\theta_K - \theta_m) + B_{Km} \sin(\theta_K - \theta_m)] + V_K V_{cR} [G_{Km} \cos(\theta_K - \delta_{cR}) + \sin(\theta_K - \delta_{cR})] + V_K V_{vR} [G_{vR} \cos(\theta_K - \delta_{vR}) + B_{vR} \sin(\theta_K - \delta_{vR})] \quad (5)$$

$$Q_K = -V_K^2 B_{KK} + V_K V_m [G_{Km} \sin(\theta_K - \theta_m) - B_{Km} \cos(\theta_K - \theta_m)] + V_K V_{cR} [G_{Km} \sin(\theta_K - \delta_{cR}) - B_{Km} \cos(\theta_K - \delta_{cR})] + V_K V_{vR} [G_{vR} \sin(\theta_K - \delta_{vR}) + B_{vR} \cos(\theta_K - \delta_{vR})] \quad (6)$$

bus m:

$$P_m = V_m^2 G_{mm} + V_m V_K [G_{mK} \cos(\theta_m - \theta_K) + B_{mK} \sin(\theta_m - \theta_K)] + V_m V_{cR} [G_{mm} \cos(\theta_m - \delta_{cR}) + B_{mm} \sin(\theta_m - \delta_{cR})] \quad (7)$$

$$Q_m = -V_m^2 B_{mm} + V_m V_K [G_{mK} \sin(\theta_m - \theta_K) - B_{mK} \cos(\theta_m - \theta_K)] + V_m V_{cR} [G_{mm} \sin(\theta_m - \delta_{cR}) - B_{mm} \cos(\theta_m - \delta_{cR})] \quad (8)$$

where:

P_K : active power of bus k, P_m : active power (bus m)

Q_K : reactive power (bus k), Q_m : reactive power (bus m)

V_K, V_m : voltage magnitudes of bus k and bus m, respectively

B_{Km}, B_{mK} : substances between connecting buses k and m

G_{Km}, G_{mK} : conductance between buses k and m, respectively

B_{mm}, B_{KK} : substances of bus k and bus m, respectively

G_{mm}, G_{kk} : conductance at bus k and n

series converter

$$P_{cR} = V_{cR}^2 G_{mm} + V_{cR} V_K [G_{Km} \cos(\delta_{cR} - \theta_K) + B_{Km} \sin(\delta_{cR} - \theta_K)] + V_{cR} V_m [G_{mm} \cos(\delta_{cR} - \theta_m) + B_{mm} \sin(\delta_{cR} - \theta_m)] \quad (9)$$

$$Q_{cR} = -V_{cR}^2 B_{mm} + V_{cR} V_K [G_{Km} \sin(\delta_{cR} - \theta_K) - B_{Km} \cos(\delta_{cR} - \theta_K)] + V_{cR} V_m [G_{mm} \sin(\delta_{cR} - \theta_m) - B_{mm} \cos(\delta_{cR} - \theta_m)] \quad (10)$$

shunt converter

$$P_{vR} = -V_{vR}^2 G_{vR} + V_{vR} V_K [G_{vR} \cos(\delta_{vR} - \theta_K) + B_{vR} \sin(\delta_{vR} - \theta_K)] \quad (11)$$

$$Q_{vR} = V_{vR}^2 B_{vR} + V_{vR} V_K [G_{vR} \sin(\delta_{vR} - \theta_K) - B_{vR} \cos(\delta_{vR} - \theta_K)] \quad (12)$$

$$\Delta P_{bb} = P_{vR} + P_{cR} = 0 \quad (13)$$

$$P_{vR} + P_{cR} = P_K + P_m = 0 \quad (14)$$

where:

P_{cR}, P_{vR} : series and shunt converters active power, respectively

Q_{cR}, Q_{vR} : series and shunt converters reactive power, respectively

ΔP_{bb} : represent the power mismatch

$$\begin{bmatrix} \Delta P_K \\ \Delta P_m \\ \Delta Q_K \\ \Delta Q_m \\ \Delta P_{mK} \\ \Delta Q_{mK} \\ \Delta P_{bb} \end{bmatrix} = \begin{bmatrix} \frac{\partial P_K}{\partial \theta_K} & \frac{\partial P_K}{\partial \theta_m} & \frac{\partial P_K}{\partial V_{vR}} V_{vR} & \frac{\partial P_K}{\partial V_m} V_m & \frac{\partial P_K}{\partial \delta_{cR}} & \frac{\partial P_K}{\partial V_{cR}} V_{cR} & \frac{\partial P_K}{\partial \delta_{vR}} \\ \frac{\partial P_m}{\partial \theta_K} & \frac{\partial P_m}{\partial \theta_m} & 0 & \frac{\partial P_m}{\partial V_m} V_m & \frac{\partial P_m}{\partial \delta_{cR}} & \frac{\partial P_m}{\partial V_{cR}} V_{cR} & 0 \\ \frac{\partial Q_K}{\partial \theta_K} & \frac{\partial Q_K}{\partial \theta_m} & \frac{\partial Q_K}{\partial V_{vR}} V_{vR} & \frac{\partial Q_K}{\partial V_m} V_m & \frac{\partial Q_K}{\partial \delta_{cR}} & \frac{\partial Q_K}{\partial V_{cR}} V_{cR} & \frac{\partial Q_K}{\partial \delta_{vR}} \\ \frac{\partial Q_m}{\partial \theta_K} & \frac{\partial Q_m}{\partial \theta_m} & 0 & \frac{\partial Q_m}{\partial V_m} V_m & \frac{\partial Q_m}{\partial \delta_{cR}} & \frac{\partial Q_m}{\partial V_{cR}} V_{cR} & 0 \\ \frac{\partial P_{mK}}{\partial \theta_K} & \frac{\partial P_{mK}}{\partial \theta_m} & 0 & \frac{\partial P_{mK}}{\partial V_m} V_m & \frac{\partial P_{mK}}{\partial \delta_{cR}} & \frac{\partial P_{mK}}{\partial V_{cR}} V_{cR} & 0 \\ \frac{\partial Q_{mK}}{\partial \theta_K} & \frac{\partial Q_{mK}}{\partial \theta_m} & 0 & \frac{\partial Q_{mK}}{\partial V_m} V_m & \frac{\partial Q_{mK}}{\partial \delta_{cR}} & \frac{\partial Q_{mK}}{\partial V_{cR}} V_{cR} & 0 \\ \frac{\partial P_{bb}}{\partial \theta_K} & \frac{\partial P_{bb}}{\partial \theta_m} & \frac{\partial P_{bb}}{\partial V_{vR}} V_{vR} & \frac{\partial P_{bb}}{\partial V_m} V_m & \frac{\partial P_{bb}}{\partial \delta_{cR}} & \frac{\partial P_{bb}}{\partial V_{cR}} V_{cR} & \frac{\partial P_{bb}}{\partial \delta_{vR}} \end{bmatrix} \begin{bmatrix} \Delta \theta_K \\ \Delta \theta_m \\ \frac{\Delta V_{vR}}{V_{vR}} \\ \frac{\Delta V_m}{V_m} \\ \Delta \delta_{cR} \\ \frac{\Delta V_{cR}}{V_{cR}} \\ \Delta \delta_{vR} \end{bmatrix} \quad (15)$$

$$\begin{bmatrix} \Delta P_K \\ \Delta P_m \\ \Delta Q_K \\ \Delta Q_m \\ \Delta P_{mK} \\ \Delta Q_{mK} \\ \Delta P_{bb} \end{bmatrix} = \begin{bmatrix} \frac{\partial P_K}{\partial \theta_K} & \frac{\partial P_K}{\partial \theta_m} & \frac{\partial P_K}{\partial V_K} V_K & \frac{\partial P_K}{\partial V_m} V_m & \frac{\partial P_K}{\partial \delta_{cR}} & \frac{\partial P_K}{\partial V_{cR}} V_{cR} & \frac{\partial P_K}{\partial \delta_{vR}} \\ \frac{\partial P_m}{\partial \theta_K} & \frac{\partial P_m}{\partial \theta_m} & \frac{\partial P_m}{\partial V_K} V_K & \frac{\partial P_m}{\partial V_m} V_m & \frac{\partial P_m}{\partial \delta_{cR}} & \frac{\partial P_m}{\partial V_{cR}} V_{cR} & 0 \\ \frac{\partial Q_K}{\partial \theta_K} & \frac{\partial Q_K}{\partial \theta_m} & \frac{\partial Q_K}{\partial V_K} V_K & \frac{\partial Q_K}{\partial V_m} V_m & \frac{\partial Q_K}{\partial \delta_{cR}} & \frac{\partial Q_K}{\partial V_{cR}} V_{cR} & \frac{\partial Q_K}{\partial \delta_{vR}} \\ \frac{\partial Q_m}{\partial \theta_K} & \frac{\partial Q_m}{\partial \theta_m} & \frac{\partial Q_m}{\partial V_K} V_K & \frac{\partial Q_m}{\partial V_m} V_m & \frac{\partial Q_m}{\partial \delta_{cR}} & \frac{\partial Q_m}{\partial V_{cR}} V_{cR} & 0 \\ \frac{\partial P_{mK}}{\partial \theta_K} & \frac{\partial P_{mK}}{\partial \theta_m} & \frac{\partial P_{mK}}{\partial V_K} V_K & \frac{\partial P_{mK}}{\partial V_m} V_m & \frac{\partial P_{mK}}{\partial \delta_{cR}} & \frac{\partial P_{mK}}{\partial V_{cR}} V_{cR} & 0 \\ \frac{\partial Q_{mK}}{\partial \theta_K} & \frac{\partial Q_{mK}}{\partial \theta_m} & \frac{\partial Q_{mK}}{\partial V_K} V_K & \frac{\partial Q_{mK}}{\partial V_m} V_m & \frac{\partial Q_{mK}}{\partial \delta_{cR}} & \frac{\partial Q_{mK}}{\partial V_{cR}} V_{cR} & 0 \\ \frac{\partial P_{bb}}{\partial \theta_K} & \frac{\partial P_{bb}}{\partial \theta_m} & \frac{\partial P_{bb}}{\partial V_K} V_K & \frac{\partial P_{bb}}{\partial V_m} V_m & \frac{\partial P_{bb}}{\partial \delta_{cR}} & \frac{\partial P_{bb}}{\partial V_{cR}} V_{cR} & \frac{\partial P_{bb}}{\partial \delta_{vR}} \end{bmatrix} \begin{bmatrix} \Delta \theta_m \\ \frac{\Delta V_K}{V_K} \\ \frac{\Delta V_m}{V_m} \\ \Delta \delta_{cR} \\ \frac{\Delta V_{cR}}{V_{cR}} \\ \Delta \delta_{vR} \end{bmatrix} \quad (16)$$




Figure 1. The basic scheme of UPFC




Figure 2. The electrical model of UPFC

2.2. Particle swarm optimization

Kennedy and Eberhart [27] proposed a PSO algorithm. This algorithm could be found in the congestion intelligence branch. This algorithm allows users to share knowledge and experiences. Simulating simplified versions of society was used to generate PSO [28]. The following is how the system works [29]:

- The process is used to research swarms like fish schools and flocks of birds.
- It is founded on basic ideas. As a result, it only uses a small amount of memory and computes quickly.
- It was designed for non-linear optimisation problems with continuous variables initially.

The velocity may be used to express this modification, and the following can be used to change the speed of each agent [30], [31]:

$$V_{id}^{Ko+1} = wV_{id}^{Ko} + C_1 \times \text{rand}(Pbest_{id} - X_{id}^{Ko}) + C_2 \times \text{rand}(Gbest_{id} - X_{id}^{Ko}) \quad (17)$$

$$X_{id}^{Ko+1} = X_{id}^{Ko} + V_{id}^{Ko+1} \quad (18)$$

where:

$i=1,2,3,\dots,n$, $d=1,2,3,\dots,m$, n . Group's number of particles, m particle members

X_{id}^{Ko} and X_{id}^{Ko+1} represent a current and modified searching point, V_{id}^{Ko} and V_{id}^{Ko+1} represents the current velocity and modified velocity, V_{pbest} and V_{gbest} represents velocity based on p_{best} and g_{best}

$Pbest$ i_{th} particle's best position, $Gbest$ is the group's best particle, w_i the agent's weight function velocity, C_1, C_2 : Acceleration constant:

$$w(i) = w_{max} - \left(\frac{w_{max} - w_{min}}{k_{o_{max}}} \right) * k_0 \quad (19)$$

where:

w_{max} , w_{min} : represent maximum and minimum weight

k_0 , $k_{o_{max}}$: represent current iteration and maximum, respectively

In this paper, the proposed PSO-based optimum PI controller with UPFC system and location design procedure is shown in Figure 3. The flow chart of this proposal is shown in Figure 4. The PSO parameters used in the proposed work are given in Table 1.




Figure 3. The proposed PSO-based optimum PI controller with UPFC system and location design procedure




Figure 4. Flow chart of the proposed PSO-based optimum PI controller with UPFC system and location design procedure

Table 1. The parameters of PSO

Parameters of PSO	
Number of particles	20
Number of iterations	100
Number of variables	5
C1, C2	1.5
W	0.5

2.3. Proportional-integral controller

The approach of selecting the parameter settings (proportional and integral) gains of the PI controller of the series and shunt converter should be chosen to increase the regulated process's stability [32]. Control loop tuning is adjusting the system parameters to achieve the best possible system outputs. From Figure 3, (K_p) represent proportional gain, (K_i) means integral gain, (V_{se}) describe the magnitude of the UPFC series voltage source converter, and (V_{sh}) represents the magnitude of the UPFC shunt voltage source converter. Each particle from the PSO search for five variables of the system, the parameters of controller K_p and K_i of the two converters series and shunt, and the optimal location of the UPFC. The total power flow losses for each particle population of the grid with UPFC were obtained from the Newton Raphson method by MATLAB code.

3. RESULTS AND DISCUSSION

The ING (46-bus) was used as the case study; the system consists of 22 generator buses and 42 load buses. Figure 5 shows the single-line diagram of the ING system. The following approach has been implemented on the ING system: two scenarios have been examined:

- Case 1: pre-optimization (without UPFC)
- Case 2: losses minimisation with UPFC installation using PSO proposed




Figure 5. ING's single-line diagram

3.1. Case 1: pre-optimization (without UPFC)

The ING (400 kV) systems are employed as test systems to validate the proposed PSO algorithm. The PSO algorithm is written in the computer programming language MATLAB. There were 73 transmission lines, bus 23 (KUTP) is the slack bus in this situation, and the ING data is based on the Iraqi Ministry of Electricity database. By modelling the ING in the MATLAB code program, the system's total active and reactive losses are 727.4593 MW, total reactive losses are 5155.9 MVAR, and total apparent power is 5207 MVA.

3.2. Case 2: losses minimization with UPFC installation using PSO proposed

The Newton-Raphson method was employed to perform load flow analysis, and loss minimization of active and reactive power losses was chosen as this work's primary goal by (20):

$$\text{objective function} = \sum_{i=1}^{Nb} \min (S_{loss}) \quad (20)$$

S_{loss} represent the total active and reactive power loss of the lines, and Nb: is the number of the transmission lines. The response of the objective function is shown in Figure 6. The PSO algorithm with PI controller suggests installing UPFC on buses (14-17), BGE4 (Baghdad)-AMN4 (Baghdad). The active and reactive power losses of the lines without UPFC and UPFC-based PSO-PI are shown in Figures 7 and 8.




Figure 6. The response of the objective function




Figure 7. The active power losses




Figure 8. The reactive power losses

Figure 9 illustrates the system's active losses decreased from 727.4593 to 579.3449 MW, while the reactive losses decreased from 5155.9 to 3971.1 MVAR, as shown in Table 2, an improvement in loss of 19% and 23%, respectively. The results of the optimization are in Table 3. The reduction in losses improves the voltage magnitude of the buses, as shown in Figure 10.




Figure 9. Total active and reactive power losses

Table 2. The total amount of active and reactive losses both before and after compensation

Losses	Without UPFC	with UPFC (PI-PSO)	Improvement (%)
P total (MW)	727.4593	594.3449	19
Q total (MVAR)	5155.9	3971.1	23
S total (MVA)	5207	4015.3	23

Table 3. The results of the proposed optimisation

PI parameters				Location of UPFC
K _{ps}	K _{is}	K _{psh}	K _{ish}	(14-17)
0.0016	6.82e-04	0.1076	0.0382	BGE4-AMN4




Figure 10. Voltage magnitude in p.u. with and without UPFC

4. CONCLUSION

The paper proposes an optimized PI controller to control the UPFC. In the proposed system, a PSO algorithm was used to find the optimum values of PI gains and the optimal location of the UPFC. This proposed method was tested on the ING system. The results show good performance has been achieved in minimizing losses. The optimal location of the UPFC was between bus 14 and bus 17, which was named BGE4 (Baghdad)-AMN4 (Baghdad), and the total active power and reactive power losses of the ING power system decreased from 727.4593 to 579.3874 MW and from 5155.9 to 3971.1 MVAR, respectively. As a result, voltage regulation was achieved. The future study can replace the PI controller with a fuzzy logic controller and compare the results from the two controllers.




REFERENCES

- [1] R. M. Mathur and R. K. Varma, *Thyristor-based facts controllers for electrical transmission systems*. New York: John Wiley & Sons, 2002, doi: 10.1109/9780470546680.
- [2] S. Marlin, S. D. S. Jebaseelan, B. Padmanabhan, and G. Nagarajan, "Power quality improvement for thirty bus system using UPFC and TCSC," *Indian Journal of Science and Technology*, vol. 7, no. 9, pp. 1316–1320, Sep. 2014, doi: 10.17485/ijst/2014/v7i9.2.
- [3] S. Alamelu, S. Baskar, C. K. Babulal, and S. Jeyadevi, "Optimal siting and sizing of UPFC using evolutionary algorithms," *International Journal of Electrical Power & Energy Systems*, vol. 69, pp. 222–231, Jul. 2015, doi: 10.1016/j.ijepes.2014.12.081.
- [4] S. Dutta, P. K. Roy, and D. Nandi, "Optimal location of UPFC controller in transmission network using hybrid chemical reaction optimization algorithm," *International Journal of Electrical Power & Energy Systems*, vol. 64, pp. 194–211, Jan. 2015, doi: 10.1016/j.ijepes.2014.07.038.
- [5] M. Mezaache, K. Chikhi, and C. Fetha, "UPFC device: Optimal location and parameter setting to reduce losses in electric-power systems using a genetic-algorithm method," *Transactions on Electrical and Electronic Materials*, vol. 17, no. 1, pp. 1–6, Feb. 2016, doi: 10.4313/TEEM.2016.17.1.1.
- [6] C. Subramani, A. A. Jimoh, S. S. Dash, and S. Harishkiran, "PSO application to optimal placement of UPFC for loss minimization in power system," in *Advances in Intelligent Systems and Computing*, 2017, pp. 223–230, doi: 10.1007/978-981-10-1645-5_19.
- [7] S. Hocine and L. Djamel, "Optimal number and location of UPFC devices to enhance voltage profile and minimizing losses in electrical power systems," *International Journal of Electrical and Computer Engineering (IJECE)*, vol. 9, no. 5, pp. 3981–3992, Oct. 2019, doi: 10.11591/ijece.v9i5.pp3981-3992.
- [8] B. Gaur, R. Ucheniya, and A. Saraswat, "Real power transmission loss minimization and bus voltage improvement using UPFC," in *International Conference on Communication, Devices and Networking*, 2020, pp. 1–9, doi: 10.1007/978-981-15-4932-8_1.
- [9] N. T. Rao, M. M. Sankar, S. P. Rao, and B. S. Rao, "Comparative study of Pareto optimal multi objective cuckoo search algorithm and multi objective particle swarm optimization for power loss minimization incorporating UPFC," *Journal of Ambient Intelligence and Humanized Computing*, vol. 12, no. 1, pp. 1069–1080, Jan. 2021, doi: 10.1007/s12652-020-02142-4.
- [10] M. Čalasan, T. Konjić, K. Kecojević, and L. Nikitović, "Optimal allocation of static var compensators in electric power systems," *Energies*, vol. 13, no. 12, pp. 1–24, Jun. 2020, doi: 10.3390/en13123219.
- [11] V. Kashyap and R. Rahangdale, "Determination of optimal location of UPFC controller devices in electric transmission system by using PSO method," *Journal of Electrical and Electronics Engineering*, vol. 11, no. 3, pp. 1–8, 2016, doi: 10.9790/1676-1103010108.
- [12] G. A. Salman, M. H. Ali, and A. N. Abdullah, "Implementation optimal location and sizing of UPFC on Iraqi power system grid (132 kV) using genetic algorithm," *International Journal of Power Electronics and Drive Systems (IJPEDS)*, vol. 9, no. 4, pp. 1607–1615, Dec. 2018, doi: 10.11591/ijpeds.v9.i4.pp1607-1615.
- [13] S. Monshizadeh, G. J. Heggliid, and S. T. Hagen, "Comparison of intelligent algorithms with FACTS devices for minimization of total power losses," in *International Conference on Advanced Information Networking and Applications*, 2020, pp. 120–131, doi: 10.1007/978-3-030-15032-7_10.
- [14] M. R. Qader, "Design and simulation of a different innovation controller-based UPFC (unified power flow controller) for the enhancement of power quality," *Energy*, vol. 89, pp. 576–592, Sep. 2015, doi: 10.1016/j.energy.2015.06.012.
- [15] P. P. Deka, D. Marsharing, D. Bordoloi, K. Deka, and S. Dey, "Application of fuzzy and PI based UPFC in electrical power system," *International Journal of Innovative Research in Electrical, Electronics, Instrumentation and Control Engineering*, vol. 4, no. 4, pp. 325–328, 2016, doi: 10.17148/IJIREEEICE.2016.4482.
- [16] H. I. El-Emari, A. Bērziņš, and J. Wang, "Optimization of the unified power flow controller based on the Imperialist competitive algorithm method," *Annals of Electrical and Electronic Engineering*, vol. 2, no. 10, pp. 1–5, Oct. 2019, doi: 10.21833/AEEE.2019.10.001.
- [17] Y. Romasevych, V. Loveikin, and S. Usenko, "Pi-controller tuning optimization via PSO-based technique," *Przegląd elektrotechniczny*, vol. 95, no. 7, pp. 33–37, Jul. 2019, doi: 10.15199/48.2019.07.08.
- [18] M. F. Roslan, A. Q. Al-Shetwi, M. A. Hannan, P. J. Ker, and A. W. M. Zuhdi, "Particle swarm optimization algorithm-based PI inverter controller for a grid-connected PV system," *PLOS ONE*, vol. 15, no. 12, pp. 1–31, Dec. 2020, doi: 10.1371/journal.pone.0243581.
- [19] L. Gyugyi, "Unified power-flow control concept for flexible AC transmission systems," *IEEE Proceedings C Generation, Transmission and Distribution*, vol. 139, no. 4, pp. 323–331, 1992, doi: 10.1049/ip-c.1992.0048.
- [20] M. Noroozian, L. Angquist, M. Ghandhari, and G. Andersson, "Use of UPFC for optimal power flow control," *IEEE Transactions on Power Delivery*, vol. 12, no. 4, pp. 1629–1634, 1997, doi: 10.1109/61.634183.
- [21] M. Zahid et al., "New approach for optimal location and parameters setting of upfc for enhancing power systems stability under contingency analysis," *Energies*, vol. 10, no. 11, pp. 1–23, Oct. 2017, doi: 10.3390/en10111738.
- [22] M. Y. Suliman and M. T. Al-Khayyat, "Power flow control in parallel transmission lines based on UPFC," *Bulletin of Electrical Engineering and Informatics*, vol. 9, no. 5, pp. 1755–1765, Oct. 2020, doi: 10.11591/eei.v9i5.2290.
- [23] C. R. Fuerte-Esquivel, E. Acha, and H. Ambriz-Perez, "A comprehensive Newton-Raphson UPFC model for the quadratic power flow solution of practical power networks," *IEEE Transactions on Power Systems*, vol. 15, no. 1, pp. 102–109, 2000, doi: 10.1109/59.852107.
- [24] B. Bhattacharyya, V. K. Gupta, and S. Kumar, "UPFC with series and shunt FACTS controllers for the economic operation of a power system," *Ain Shams Engineering Journal*, vol. 5, no. 3, pp. 775–787, Sep. 2014, doi: 10.1016/j.asej.2014.03.013.
- [25] A. A. Ahmad and R. Sirjani, "Optimal placement and sizing of multi-type FACTS devices in power systems using metaheuristic optimisation techniques: An updated review," *Ain Shams Engineering Journal*, vol. 11, no. 3, pp. 611–628, Sep. 2020, doi: 10.1016/j.asej.2019.10.013.
- [26] R. H. AL-Rubayi and L. G. Ibrahim, "Enhancement transient stability of power system using UPFC with M-PSO," *Indonesian Journal of Electrical Engineering and Computer Science*, vol. 17, no. 1, pp. 61–69, Jan. 2020, doi: 10.11591/ijeecs.v17.i1.pp61-69.
- [27] R. Eberhart and J. Kennedy, "New optimizer using particle swarm theory," *Proc. Int. Symp. Micro Mach. Hum. Sci.*, pp. 39–43, 1995, doi: 10.1109/mhs.1995.494215.
- [28] Y. del Valle, G. K. Venayagamoorthy, S. Mohagheghi, J.-C. Hernandez, and R. G. Harley, "Particle swarm optimization: Basic concepts, variants and applications in power systems," *IEEE Transactions on Evolutionary Computation*, vol. 12, no. 2, pp. 171–195, Apr. 2008, doi: 10.1109/TEVC.2007.896686.




- [29] Y. Shi and R. Eberhart, "A modified particle swarm optimizer," in *1998 IEEE International Conference on Evolutionary Computation Proceedings. IEEE World Congress on Computational Intelligence (Cat. No.98TH8360)*, 1998, pp. 69–73, doi: 10.1109/ICEC.1998.699146.
- [30] M. R. AlRashidi and M. E. El-Hawary, "A survey of particle swarm optimization applications in electric power systems," *IEEE Transactions on Evolutionary Computation*, vol. 13, no. 4, pp. 913–918, Aug. 2009, doi: 10.1109/TEVC.2006.880326.
- [31] R. Al-Rubayi and M. Eese, "Optimal location and parameter setting of STATCOM device based PSO for Iraqi grid voltage profile enhancement and power losses minimizing," *Engineering and Technology Journal*, vol. 37, no. 2A, pp. 60–69, Feb. 2019, doi: 10.30684/etj.37.2A.4.
- [32] I. Amin, D. Mahmood, and A. Numan, "Optimal localization of UPFC for transmission line losses minimizing using particle swarm optimization," *Engineering and Technology Journal*, vol. 39, no. 10, pp. 1463–1472, Oct. 2021, doi: 10.30684/etj.v39i10.1656.

BIOGRAPHIES OF AUTHORS






Shaimaa A. Hussein    received the B.Sc in in Electrical Engineering from the University of technology in 2002. She is currently studying for a Masters's degree of Science in Electrical power Engineering at the University of Technology, Iraq. She can be contacted at email: eee.20.56@grad.uotechnology.edu.iq.



Dhari Yousif Mahmood    is a Prof. at the Department of Electrical Engineering at the University of Technology–Baghdad–Iraq. He was awarded his M.Sc and Ph.D. in Electrical Power Engineering from Sant. Peterburg Polytechnical Institute–Russia in 1986 and 1990, respectively. His BSc degree was received in 1981 from the University of Baghdad–Collage of Engineering–Iraq. He works in the field of renewable energy and power system analysis. He supervises a large number of postgraduate students with both Master's and Ph.D. degrees. He can be contacted at email: dhari.y.mahmood@uotechnology.edu.iq.



Ali Hussein Numan    received the BSc, M.Sc, and Ph.D. in Electrical Engineering from the University of Technology, in 1999, 2003, and 2009, respectively. Currently, he is an Associate Professor of Electrical Engineering in the Electromechanical Engineering Department of the University of Technology (UoT). He has co-authored the textbook *Small and Special Electric Motor and Their Control Technique*, 2016, and published 48 journals and conference papers. His research interests include power electronics, variable speed drives, renewable energy, and modelling and simulation. He can be contacted at email: ali.h.numan@uotechnology.edu.iq.